STATE FIRE MARSHAL DRAFT OF PROPOSED CHANGES TITLE 24, PART 2, CALIFORNIA BUILDING CODE

904.1.2 Standards. Fire-extinguishing systems shall comply with UBC Standards 9-1 and 9-2. **[For SFM]** Fire-extinguishing systems shall comply with the standards in Chapter 35. The following standards in Chapter 35 shall be utilized:

NFPA 11-1994 Foam Extinguishing Systems; NFPA 11A-1994, Medium- and High-Expansion Foam Systems; NFPA 12-1997, Carbon Dioxide Fire Extinguishing Systems; NFPA 12A, 1992, Halon 1301 Systems; NFPA 2001-1996, Clean Agent Fire Extinguishing Systems; NFPA 13-1999 as amended, Installation of Sprinkler Systems; NFPA 13D-1999, Installation of Sprinkler Systems in One- and Two-Family Dwellings and Mobile Homes (Installed in Congregate Living Health Facilities); NFPA 13R-1999, Installation of Sprinkler Systems in Residential Occupancies Up to and Including Four Stories in Height; NFPA 14-2000, Standpipe and Hose Systems; NFPA 15-1996, Water Spray Fixed Systems; NFPA 16A-1994, Closed-head Foam-water Sprinkler Systems; NFPA 17-1994, Dry Chemical Extinguishing Systems; NFPA 17A-1994, Wet Chemical Extinguishing Systems; NFPA 20-1996, Centrifugal Fire Pumps; NFPA 22-1996, Water Tanks for Private Fire Protection; NFPA 24-1995, Private Fire Service Mains (except as noted in Section 904.1.2, Exception 2).

